



Product Service

Attestation of Conformity

No. E8A 16 11 73342 149

Holder of Certificate: **Sungrow Power Supply Co., Ltd.**No. 1699 Xiyou Road, New & High
Technology Industrial Development Zone,
230088 Hefei, Anhui
PEOPLE'S REPUBLIC OF CHINA**Name of Object:** **Converter**
PV Grid Connected Inverter**Model(s):** **SG36KTL-M****Description of Object:**

Input voltage:	DC 200V~1100V
Max. input power:	40KW
Rated output voltage:	400VAC/3Ø
Rated frequency:	50Hz
Rated output power:	36KW
Protection class:	I

Tested according to: EN 61000-6-2:2005
EN 61000-6-3:2007/A1:2011

This Attestation of Conformity is issued on a voluntary basis according to the Directive 2014/30/EU relating to electromagnetic compatibility. It confirms that the listed apparatus complies with all essential requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: 4842016260400*Jun Bao***Date,** 2016-12-06 (Jun Bao)

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. That declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

Page 1 of 1